



**NOTE 1:** FOR 277 VAC APPLICATIONS, R1 & R2 MUST BE 3 POLE RELAYS FOR REQUIRED ADDED CONTROL VOLTAGE CONTACTS.